

# DUMPSBOSS.COM

## Huawei Certified Pre-Sales Specialist - UPS

Huawei H19-311

Version Demo

Total Demo Questions: 15

Total Premium Questions: 225

Buy Premium PDF

<https://dumpsboss.com>

[support@dumpsboss.com](mailto:support@dumpsboss.com)

dumpsboss.com



**QUESTION NO: 1**

Which of the following statements are incorrect about the UPS 5000-A-400/500K? (Multiple Choice)

- A. The input power factor is 0.99.
- B. The output power factor is 1.
- C. The number of batteries cannot be adjusted.
- D. The efficiency is 94%.

**ANSWER: B C D**

**QUESTION NO: 2**

Which of the following statements are true about the overload capabilities of the various capacity models of the UPS2000-A series (6 kVA to 10 kVA) in normal mode? ( ) (Multiple Choice)

- A. 105%-125%, switch to bypass after 5-minute continuous loading
- B. 125%-150%, switch to bypass after 1-minute continuous loading
- C. > 150%, switch to bypass after 10s continuous loading
- D. > 150%, switch to bypass after 0.1s continuous loading

**ANSWER: A B D**

**QUESTION NO: 3**

The standard UPS5000-A is equipped with an LCD which supports multiple languages, displays system operating system in real time, and stores a maximum of ( ) alarm records.

- A. 2000
- B. 2500
- C. 3000

**ANSWER: B**

**QUESTION NO: 4**

The battery voltage of the UPS2000-G is 240 V for the 6-10 kVA capacity models, and is 480 V for the 15 kVA and 20 kVA capacity models.

- A. TRUE
- B. FALSE

**ANSWER: A**

#### QUESTION NO: 5

The UPS2000-G series (6 kVA to 20 kVA) supports up to () UPSs in parallel, providing excellent scalability.

- A. 0
- B. 2
- C. 3
- D. 4

**ANSWER: D**

#### QUESTION NO: 6

Batteries of different discharge currents have different requirements for the cutoff voltage. Typically, the () the discharge current is, the () the cutoff voltage is.

- A. Higher, higher
- B. Lower, higher
- C. Lower, lower

**ANSWER: B**

#### QUESTION NO: 7

Which of the following are the functions of the SCT configurator? () (Multiple Choice)

- A. Display product cost data
- B. Provide quick overview of Huawei products
- C. Quick solution configuration
- D. Simple quotation creation

**ANSWER: B C D****QUESTION NO: 8**

Electric cables are determined on actual project requirements during UPS configuration.

- A. TRUE
- B. FALSE

**ANSWER: A****QUESTION NO: 9**

Which of the following are the optional components for the UPS2000-G series (6 kVA to 20 kVA)? ( ) (Multiple Choice)

- A. Temperature and humidity sensor
- B. Battery temperature sensor
- C. Transformer
- D. PDU

**ANSWER: A B C D****QUESTION NO: 10**

The optional components and features in the typical configuration solution of the FusionModule800 include ( ).

- A. Temperature and humidity sensor, door status sensor, water sensor, smoke sensor, and mobile app
- B. Smoke sensor, door status sensor, water sensor, alarm notification over short messages, and Huawei tablet
- C. Door magnetic switch, Water leakage, Video system. Power backup system, iBattery, Mobile APP (remote), Emergency fans

**ANSWER: C****QUESTION NO: 11**

Which of the following UPS types does the PS5000-E (50 kVA power module) belongs to? (Multiple Choice)

- A. Industrial frequency UPS
- B. High frequency UPS

C. Rack and tower-mounted UPS

D. Modular UPS

**ANSWER: B D**

**QUESTION NO: 12**

The UPS5000-E can realize convenient and simple 2N power supply system only by configuring a ().

A. BSC cable

B. Synchronized control

C. BSC control board

D. Parallel card

**ANSWER: A**

**QUESTION NO: 13**

Which of the following products can be quoted in a configurator? (Multiple Choice)

A. UPS2000-G

B. UPS5000-E

C. FusionModule2000

D. UPS8000

**ANSWER: A B C**

**QUESTION NO: 14**

The UPS5000-A 30-120 kVA can be wall-mounted.

A. TRUE

B. FALSE

**ANSWER: B**

**QUESTION NO: 15**

What's difference of a traditional industrial frequency UPS compared with high frequency UPS? (Multiple Choice)

- A.** The rectifier system is different.
- B.** A built-in boosting transformer is required for output.
- C.** The bypass component type is different.
- D.** All of the above are correct.

**ANSWER: A B**

DUMPSBOSS.COM